

zebx DecarbLunch Series

Powered by **ZEIC**

Building Decarbonization in Cold Climates

Fri Jan 24, 2025
12 - 1pm PST
Free Webinar
zebx.org



B2E
Building to
Decarbonize



CREATIVENERGY
YOUR COMMUNITY ENERGY PARTNER



Natural Resources
Canada

Ressources naturelles
Canada

Canada



Electrification in Colder Climates

Case Study



Orion: Real-Life Performance of a Step 4, All-Electric Building

Nov 24, 2022

Case Study



Is Using a Heat Pump in the North Feasible?

Jun 8, 2022

Resource



Scalable Decarbonization Opportunities in Commercial Buildings

May 25, 2023

Electrification in Colder Climates



COLD CLIMATE DECARBONIZING Geoexchange Applications in Harsh Climates


Jeff Quibell, P.Eng.
January 24, 2025

zebx
ZERO EMISSIONS BUILDING EXCHANGE

Objectives this Afternoon

1. Climate zones – BC distribution
2. Challenges to decarbonize in harsh climates
3. Geoexchange heat pumps.....***Ultimate Cold Climate Heat Pumps***
4. Design adaptations for harsh climates
5. Misperceptions
6. Obstacles and pathways to overcome

Geoexchange Fundamentals




Source: Natural Resources Canada

Terms

- Geoexchange
- Geothermal
- Ground Source Heat Pump (GSHP)
- Earth Energy Systems

Geoexchange Fundamentals




Source: Natural Resources Canada

Attractive Features


- Avoided noise, improved architectural aesthetics
- Season-to-season energy store
- District-scale energy leveraging benefits
- Very efficient – including extreme conditions
- ***Ultimate Cold Climate Heat Pump***

Big Nation... *Lots of Harsh Climate*




Adapted from National Research Council of Canada

Big Province... *Lots of Harsh Climate*



Adapted from National Research Council of Canada

Leveraging Ratio - Coefficient of Performance (COP)



$$\text{Coefficient of Performance} = \frac{\text{Heat Delivered (4.0 units)}}{\text{Electricity Used (1.0 unit)}} = 4.0$$


New Build School - Northern BC

Shas Ti Kelly Road Secondary School, Prince George, BC

- 9,595 m²
- 280 kW Geexchange Heat Pump System



Source: HMCA Architecture, SD57



Shas Ti Kelly Road Secondary School, Prince George, BC


Utility Data	Actual GeoX 2021	Conventional Comparable
Natural Gas	7 kWh/m ²	110 kWh/m ²
Electricity	68 kWh/m ²	110 kWh/m ²
Combined Gas + Elec	75 kWh/m ²	220 kWh/m ²
GHG Emissions (CO ₂ e)	19.7 tonnes/yr	201 tonnes/yr
Energy Savings	\$83,600/yr	-
Avoided GHG Emissions	181 tonnes/yr	-



Retrofit GeoX Upgrade - Northern BC

Ecole Frank Ross Elementary, Dawson Creek, BC

- 5,100 m²
- 210 kW Georexchange Heat Pump System
- 1950s era original wing, 1960s era addition



Ecole Frank Ross Elementary, Dawson Creek, BC

Utility Data	Actual GeoX 2022	Pre-Retrofit Comparison
Natural Gas	11 kWh/m ²	215 kWh/m ²
Electricity	79 kWh/m ²	44 kWh/m ²
Combined Gas + Elec	90 kWh/m ²	259 kWh/m ²
GHG Emissions (CO ₂ e)	14.2 tonnes/yr	198.5 tonnes/yr
Energy Savings	\$18,300/yr	-
Avoided GHG Emissions	184 tonnes/yr	-



Ecole Frank Ross – Temperature Monitoring – Dawson Creek


This week: 4-day Period Jan 17 to Jan 20, 2025



Generated by FALCON-JEFFQ (January 20, 2025 16:32:54 pm)


South Peace Secondary – Temperature Monitoring – Dawson Creek

This week: 3-day Period Jan 18 to Jan 20, 2025




Generated by FALCON-JEFFQ (January 20, 2025 16:28:45 pm)

Annual Temperature Monitoring – Williams Lake Example



Cold Climate Design Considerations

- Elongated open borehole layouts
- Reduce bore-to-bore interference



Uptake Obstacles...and Opportunities

Heat Pumps... Not Drop-in Replacements for Boilers





Boilers

≠



Heat Pumps

BC Geology Settings – Adapt Designs to Suit Settings



Rocky Mountain Front Ranges

Foothills

Prairies

Recap

- Geoexchange is suited in many settings for different reasons
- Exceptional cold climate performance leads to attractive suitability in northern regions – *Ultimate Cold Climate Heat Pump*
- Demonstrated high-performance outcomes
- High-performance conditional on appropriately adapted designs

Take-aways:


1. Geoexchange warrants routine consideration in northern settings
2. Geoexchange has unique potential to significantly decarbonise heating in northern climates

CREATIVENERGY

DESIGN CONSIDERATIONS FOR AIR SOURCE
HEAT PUMPS SYSTEMS IN COLD CLIMATES
Keith Bate P.Eng.

January 24th, 2025





$$\text{Coefficient of Performance (CoP)} = \frac{\text{HEATING (or COOLING) ENERGY SUPPLIED}}{\text{ELECTRICAL INPUT}}$$

Technology this presentation is not about...



Individual split heat pump systems



VRF (Variable Refrigerant Flow) systems




Gas absorption heat pumps

Thompson Rivers University Project Overview


- University founded in 1970 in Kamloops, BC
- Winter 1% design temp of -25°C (-13°F)
- Existing buildings with gas boilers and gas roof top units
- Variety of terminal units
- Design heating water temperatures of up to 90°C

System Design Considerations


- 'Stress test' identified that most buildings could work at 65°C but system needed to be capable of higher temperature operation
- 7.5MW peak heating demand
- 3MW of low carbon capacity achieves 95%+ GHG reductions
- Limit on electrical service of 2.5 MVA to avoid BC Hydro upgrade




Load Duration Curve - Typical Weather



Options assessment



ASHP Operating Limits, Capacity and Coefficient of Performance



365 kW
CoP = 2.15

366 kW
CoP = 2.50

827 kW
CoP = 4.91


731 kW
CoP = 2.47

957 kW
CoP = 4.28


529 kW
CoP = 9.87

591 kW
CoP = 7.98

Two Stage Heat Pump Solution



Two Stage Heat Pump Solution



Net CoP Comparison

at -15°C

at +15°C



■ Electricity
■ Air

CoP of 2.36



Air Source
Heat Pump

CoP of 4.35




■ Electricity
■ Air

+




■ Electricity
■ Intermediate Loop

CoP of 4.24



Water to water
heat pump

CoP of 4.24



■ Electricity
■ Intermediate Loop


=



■ Electricity
■ Air


Net CoP of 1.79

$$4.24 / (1 + 3.24/2.36)$$



Net CoP of 2.43


$$4.24 / (1 + 3.24/4.35)$$




■ Electricity
■ Air

Defrost

Normal operation



Defrost mode



Role of Buffer Tank / Electric Boiler


- Volume of piping loop ~ 5,000 litres
- Volume of buffer tanks – 4,500 litres

With one ASHP in defrost mode intermediate loop temperature drops...





- 2.3°C per minute without buffer tanks
- 1.2 °C per minute with buffer tanks

Benefits of electric boiler in intermediate loop:



- Tops up when ASHPs cannot provide enough heat for the water to water heat pumps (below approximately -7°C)
- Below -18°C ASHPs turn off – electric boiler provides all heat to the water to water heat pumps
- Prevents ‘death spiral’ where intermediate loop temperature is too low for air source heat pumps to work



Computational Fluid Dynamic Modeling of Airflow



Future Developments - Natural Refrigerants



Summary

- Air source heat pumps can be a viable decarbonization strategy in cold climates
 - Systems sized for only part of peak heating load can provide significant GHG reductions
 - Consider noise mitigation and ensure adequate airflow when locating equipment
 - Two stage systems can provide higher heating water temperatures
 - Ensure freeze protection measures are in place
 - Account for the impact of defrost cycles in system design
 - Ensure air source heat pump loop temperature can be maintained in operating range
 - Consider natural refrigerants for lower environmental impact and future proof systems
- 